

Certificate of Product Approval

Certificate Number: 126bs

Issue: 01

Siemens Switzerland Limited

Building Technologies Division
Gubelstrasse 22
Zug
CH-6301
Switzerland



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and indicating equipment

FC121-ZA

FC122-ZA

FC123-ZA

FC124-ZA

(refer to Appendix for details)

Standards

EN 54-13:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

W Hunukumbure
Verifier

11 September 2014
Date of Issue

11 September 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 126bs Siemens Switzerland Limited

Issue: 01

Certified Product	Description	LPCB Ref.No.
	<u>Control and indicating equipment</u>	126bs/01
FC121-ZA	Two zone conventional control and indicating equipment	
FC122-ZA	Four zone conventional control and indicating equipment	
FC123-ZA	Eight zone conventional control and indicating equipment	
FC124-ZA	Twelve zone conventional control and indicating equipment	
	<u>Power Supply</u>	
	FP2015-A1 CIE internal power supply	
	<u>Output Device</u>	
	FCA1209-Z1 Output Module	
	<u>Input / Output Device</u>	
	DC1192 Input/output module with short circuit isolator	
	<u>Commercial Detectors</u>	
	FDOOT241-9 Analogue addressable multisensor detector with short circuit isolator	
	FDOOT241-A9 Multisensor detector with short circuit isolator	
	FDL241-9 Analogue addressable beam detector with short circuit isolator	
	OH320C Conventional photoelectric smoke detector with thermal enhancement	
	OOH740 Analogue addressable multisensor detector with short circuit isolator	
	DO1101A-Ex Intrinsically safe conventional photoelectric smoke detector	
	DT1101A Conventional class A1R heat detector	
	DT1101A-Ex Conventional intrinsically safe class A1R heat detector	
	DT1102A Conventional class B heat detector	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

W Hunukumbure

Signed for LPCB

W Hunukumbure
Verifier

11 September 2014
Date of Issue

11 September 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




bre

Appendix to Certificate No: 126bs Siemens Switzerland Limited

Issue: 01

Certified Product	Description	LPCB Ref.No.
	DT1102A-Ex Conventional intrinsically safe class B heat detector DO1101A Conventional photoelectric smoke detector HI320C Conventional class A1R heat detector HI322C Conventional class A2 heat detector OP320C Conventional photoelectric smoke detector <u>Flame Detectors</u> FDF221-9 Analogue addressable infra red flame detector with short circuit isolator FDF241-9 Analogue addressable infra red flame detector with short circuit isolator DF1191 Analogue addressable infra red flame detector with short circuit isolator DF1192 Analogue Addressable Infra Red Flame Detector <u>Manual Call Points</u> DM1101 Indoor manual call point, flush mounted DM1104 Conventional indoor and outdoor manual call point MT320C Conventional indoor and outdoor manual call point FDM1101-RG Collective Type A Indoor / Outdoor Manual Call Point with Non-Resetable Glass Element FDM1101-RP Collective Type A Indoor / Outdoor Manual Call Point with Resettable Plastic Element FDM1101A-RG Conventional Type A Indoor / Outdoor Manual Call Point with Non-Resetable Glass Element FDM1101A-RP Conventional Type A Indoor / Outdoor Manual Call Point with Resettable Plastic Element FDM1101-RG(F) Collective Type A Indoor / Outdoor Manual Call Point with Non-Resetable Glass Element FDM1101-RP(F) Collective Type A Indoor / Outdoor Manual Call Point with Resettable Plastic Element; French labelling on Resettable Plastic Element.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

W Hunukumbure
Verifier

11 September 2014
Date of Issue

11 September 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Appendix to Certificate No: 126bs Siemens Switzerland Limited

Issue: 01

Certified Product	Description	LPCB Ref.No.
	<p><u>Alarm Warning Devices</u> FDSB292 Analogue conventional (collective) sounder base ROLP Roshni Conventional Type A/B LP Sounder</p> <p><u>General note:</u> For further information on each individual product including approved sensitivities, heat classification, sounder tones etc, refer to model reference number(s) in the appropriate section of the Red Book or on www.redbooklive.com</p>	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

W Hunukumbure
Verifier

11 September 2014
Date of Issue

11 September 2014
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com