

## Certificate of Product Approval

Certificate Number: 531q-(cl-1) Issue: 02

### Siemens Switzerland Limited

Building Technologies Division  
 Gubelstrasse 22  
 Zug  
 CH-6301  
 Switzerland



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

**Products:**

Control and indicating equipment  
 FC121-ZA and FC122-ZA  
 FC123-ZA and FC124-ZA  
 (refer to Appendix for details)

**Standards:**

EN 54-2: 1997 + A1: 2006  
 EN 54-4: 1998 + A1: 2002 + A2: 2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Wasantha Hunukumbure	04 February 2014	04 February 2014
Signed for LPCB	Verifier	Date of First Issue



This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).  
 To check the validity of this certificate please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR Tag or contact us.  
 T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
 LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.



## Appendix to Certificate Number: 531q-(cl-1) Siemens Switzerland Limited

Issue: 02

Certified Products	Description	LPCB Ref. No.
FC121-ZA and FC122-ZA	<p>FC121-ZA Two zone conventional control and indicating equipment FC122-ZA Four zone conventional control and indicating equipment</p> <p>Incorporating the units: PCBA FC121-ZA Two zone main control board with integrated power supply PCBA FC122-ZA Four zone main control board with integrated power supply</p> <p>Optional modules: FCA1203-Z1 Output card 2M2R FTO1201-H1 EVAC module (applicable on NL model only) FCA1206-Z1 Key switch set ( applicable on Nordic SE model only)</p> <p>Certified with the following options with requirements from EN 54-2: 1997</p> <ul style="list-style-type: none"> <li>7.8 Output to fire alarm devices</li> <li>7.9.1 Output to fire alarm routing equipment</li> <li>7.9.2 Alarm confirmation input from fire alarm routing equipment</li> <li>7.10.1 Outputs to fire protection equipment (Type A)</li> <li>7.11 Delays to outputs</li> <li>7.12.1 Dependencies on more than one alarm signal (Type A dependency)</li> <li>7.12.2 Dependencies on more than one alarm signal (Type B dependency)</li> <li>7.13 Alarm counter</li> <li>8.9 Output to fault warning routing equipment</li> <li>10 Test condition</li> </ul>	531q/01
FC123-ZA and FC124-ZA	<p>FC123-ZA Eight zone conventional control and indicating equipment FC124-ZA Twelve zone conventional control and indicating equipment</p>	531q/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Wasantha Hunukumbure

04 February 2014

04 February 2014

Signed for LPCB

Verifier

Date of Issue

Date of First Issue



This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR Tag or contact us.

T: +44 (0)1923 664100 F : +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is part of BRE Global Ltd., Garston, Waford WD25 9XX.




## Appendix to Certificate Number: 531q-(cl-1) Siemens Switzerland Limited

Issue: 02

Certified Products	Description	LPCB Ref. No.
	<p>Incorporating the units:                      PCBA FC 123-ZA Eight zone main control board                      PCBA FC 124-ZA Twelve zone main control board                      FP2015-A1 Power supply (70W)</p> <p>Optional modules:                      FCA1203-Z1 Output card 2M2R                      FTO1202-Z1 Zone indication field 12x2 LED                      FTO1203-H1 EVAC module (applicable on NL model only)                      FCA1206-Z1 Key switch set ( applicable on Nordic SE model only)</p> <p>Certified with the following options with requirements from EN 54-2: 1997</p> <ul style="list-style-type: none"> <li>7.8 Output to fire alarm devices</li> <li>7.9.1 Output to fire alarm routing equipment</li> <li>7.9.2 Alarm confirmation input from fire alarm routing equipment</li> <li>7.10.1 Outputs to fire protection equipment (Type A)</li> <li>7.11 Delays to outputs</li> <li>7.12.1 Dependencies on more than one alarm signal (Type A dependency)</li> <li>7.12.2 Dependencies on more than one alarm signal (Type B dependency)</li> <li>7.13 Alarm counter</li> <li>8.9 Output to fault warning routing equipment</li> <li>10 Test condition</li> </ul>	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Wasantha Hunukumbure 04 February 2014

04 February 2014

Signed for LPCB

Verifier

Date of Issue

Date of First Issue



This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).  
 To check the validity of this certificate please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR Tag or contact us.  
 T: +44 (0)1923 664100 F : +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
 LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.


