LPCB®

Certificate of Product Approval

Certificate Number: 126aw-(cl-2)   Issue: 02

Siemens Switzerland Limited

Building Technologies Division
Gubelstrasse 22
Zug
CH-6301
Switzerland

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

Products:	Standards:
Control and indicating equipment	EN 54-2: 1997 + A1: 2006
	EN 54-4: 1997 + A1: 2002 + A2: 2006
FT724	
FC726	
FC724	
FC722	
FC721	
(refer to Appendix for details)	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Verifier	Date of Issue	Date of First Issue
	Wasantha Hunukumbure	21 October 2013	21 March 2011

LPCB®

Appendix to Certificate Number: 126aw-(cl-2) Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
FC721	Control and indicating equipment Incorporating as modular units: FCM7204-Z3 Operating unit FP2001-A1 70W Power supply FCI2010-A1 Periphery board (1-Loop) FHA2002-A1 Rear housing and as optional modular units: FCM7205-Y3 Operating unit (+ LED Ind.) FCM7203-H3 Operating unit (+ EVAC-Term.) FCM2027 PMI- & mainboard FTO2001-A1 Event printer FTO2002-A1 24 LED indicator (internal) FN2001-A1 Networking module (See Note 1) FCA2001-A1 Isolated RS232 module FCA2002-A1 Isolated RS485 module Certified with the following Options with requirements from EN 54-2: 7.8 Output to fire alarm devices 7.9.1 Output to fire alarm routing equipment 7.9.2 Alarm Confirmation from fire alarm routing equipment 7.10.1 Output to automatic fire protection equipment Type A 7.10.2 Output to automatic fire protection equipment Type B 7.10.3 Output to automatic fire protection equipment Type C 7.10.4 Fault monitoring of automatic fire protection equipment 7.11 Delays to outputs 7.12.2 Coincidence detection type B (only for FDnet & MS9i line technology) 7.12.3 Coincidence detection type C 7.13 Alarm counter	126aw/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Wasantha Hunukumbure	21 October 2013	21 March 2011
	Verifier	Date of Issue	Date of First Issue

Appendix to Certificate Number: 126aw-(cl-2)   Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disablement of addressable points 10 Test condition Note: 1. Scope of approval does not include the operation of the network functionality. 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	
FC722	Control and indicating equipment Incorporating as modular units: FCM7204-Z3 Operating unit SV24V/150W 150W Power supply FCI2002-A1 Periphery board (2-Loop) FHA2003-A1 Rear housing and as optional modular units: FP2001-A1 70W Power supply FHA2001-A1 Rear housing FCM7205-Y3 Operating unit (+ LED Ind.) FCM7203-H3 Operating unit (+ EVAC-Term.) FCM2027 PMI- & mainboard FTO2001-A1 Event printer FCI2003-A1 Loop extension (FDnet) FTO2002-A1 24 LED indicator (internal) FN2001-A1 Networking module (See Note 1) FN2008-A1 Ethernet Switch (See Note 1) FCA2001-A1 Isolated RS232 module FCA2002-A1 Isolated RS485 module FCI2001-D1 Fire brigade periphery module	126aw/06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

(signature)	Wasantha Hunukumbure 21 October 2013	21 March 2011
Signed for LPCB	Verifier Date of Issue	Date of First Issue

LPCB®

Appendix to Certificate Number: 126aw-(cl-2)   Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	REDUX Redundancy module Certified with the following Options with requirements from EN 54-2: 7.8 Output to fire alarm devices 7.9.1 Output to fire alarm routing equipment 7.9.2 Alarm Confirmation from fire alarm routing equipment 7.10.1 Output to automatic fire protection equipment Type A 7.10.2 Output to automatic fire protection equipment Type B 7.10.3 Output to automatic fire protection equipment Type C 7.10.4 Fault monitoring of automatic fire protection equipment 7.11 Delays to outputs 7.12.2 Coincidence detection type B (only for FDnet & MS9i line technology) 7.12.3 Coincidence detection type C 7.13 Alarm counter 8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disablement of addressable points 10 Test condition Note: 1. Scope of approval does not include the operation of the network functionality. 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	
FC724	Control and indicating equipment Incorporating as modular units: FCM7204-Z3 Operating unit SV24V/150W 150W Power supply FCI2004-A1 Periphery board (4-Loop)	126aw/07

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Wasantha Hunukumbure Verifier	21 October 2013 Date of Issue
		21 March 2011 Date of First Issue

Appendix to Certificate Number: 126aw-(cl-2) Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	FHA2003-A1 Rear housing	
	and as optional modular units:	
	FCM7205-Y3 Operating unit (+ LED Ind.)	
	FCM7203-H3 Operating unit (+ EVAC-Term.)	
	FCM2027 PMI- & mainboard	
	FCM2007-A2 Operating add-on module (4 LED ind.)	
	FTO2001-A1 Event printer	
	FCI2003-A1 Loop extension (FDnet)	
	FTO2002-A1 24 LED indicator (internal)	
	FN2001-A1 Networking module (See Note 1)	
	FN2008-A1 Ethernet Switch (See Note 1)	
	FCA2001-A1 Isolated RS232 module	
	FCA2002-A1 Isolated RS485 module	
	FCI2001-D1 Fire brigade periphery module	
	REDUX Redundancy module	
	Certified with the following Options with requirements from EN 54-2:	
	7.8 Output to fire alarm devices	
	7.9.1 Output to fire alarm routing equipment	
	7.9.2 Alarm Confirmation from fire alarm routing equipment	
	7.10.1 Output to automatic fire protection equipment Type A	
	7.10.2 Output to automatic fire protection equipment Type B	
	7.10.3 Output to automatic fire protection equipment Type C	
	7.10.4 Fault monitoring of automatic fire protection equipment	
	7.11 Delays to outputs	
	7.12.2 Coincidence detection type B (only for FDnet & MS9i line technology)	
	7.12.3 Coincidence detection type C	
	7.13 Alarm counter	
	8.3 Fault signals from points	
	8.9 Output to fault warning routing equipment	
	9.5 Disablement of addressable points	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Wasantha Hunukumbure	21 October 2013	21 March 2011
	Verifier	Date of Issue	Date of First Issue

LPCB®

www.redbooklive.com

Appendix to Certificate Number: 126aw-(cl-2) Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	10 Test condition Note: 1. Scope of approval does not include the operation of the network functionality. 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	
FC726	Control and indicating equipment Incorporating as modular units: FCM7204-Z3 Operating unit SV24V/150W 150W Power supply FCI2004-A1 Periphery board (4-Loop) FHA2005-A1 Rear housing FCA2008-A1 Card cage (5 slot) and as optional modular units: FCM7205-Y3 Operating unit (+ LED Ind.) FCM2027 PMI- & mainboard FCM2007-A2 Operating add-on module (4 LED ind.) FCM2015-DA Operating add-on module (DA ind.) FTO2001-A1 Event printer FCI2003-A1 Loop extension (FDnet) FTO2002-A1 24 LED indicator (internal) FN2001-A1 Networking module (See Note 1) FN2008-A1 Ethernet Switch (See Note 1) FCA2001-A1 Isolated RS232 module FCA2002-A1 Isolated RS485 module FCI2001-D1 Fire brigade periphery module FTO2003-D1 Emergency alarm indicator FCA2006-A1 Connection mod. (Card Cage)	126aw/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

W. Hunukumbure	Wasantha Hunukumbure 21 October 2013	21 March 2011
Signed for LPCB	Verifier Date of Issue	Date of First Issue

LPCB — LOSS PREVENTION CERTIFICATION BOARD

UKAS PRODUCT CERTIFICATION 007

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate please visit www.redbooklive.com/check, scan the QR Tag or contact us.

T: +44 (0)1923 664100   F : +44 (0)1923 664603   E: enquiries@breglobal.com
LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.

bre

Rev0.0

Page 6 of 8

© BRE Global Ltd, 2012

Appendix to Certificate Number: 126aw-(cl-2) Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	FCI2008-A1 I/O card (programmable) FCL2001-A1 Line card (FDnet) FCL2002-A1 Line card (collective) FCL2003-A1 Line card (MS9i) REDUX Redundancy module Certified with the following Options with requirements from EN 54-2: 7.8 Output to fire alarm devices 7.9.1 Output to fire alarm routing equipment 7.9.2 Alarm Confirmation from fire alarm routing equipment 7.10.1 Output to automatic fire protection equipment Type A 7.10.2 Output to automatic fire protection equipment Type B 7.10.3 Output to automatic fire protection equipment Type C 7.10.4 Fault monitoring of automatic fire protection equipment 7.11 Delays to outputs 7.12.1 Coincidence detection type A (only for MS9i & collective line technology) 7.12.2 Coincidence detection type B (only for FDnet & MS9i line technology) 7.12.3 Coincidence detection type C 7.13 Alarm counter 8.3 Fault signals from points 8.9 Output to fault warning routing equipment 9.5 Disablement of addressable points 10 Test condition Note: 1. Scope of approval does not include the operation of the network functionality. 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	
FT724	Fire detection terminal for use with FC721, FC722 & FC724 control and	126aw/R02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Wasantha Hunukumbure Verifier	21 October 2013 Date of Issue	21 March 2011 Date of First Issue

Appendix to Certificate Number: 126aw-(cl-2)   Issue: 02
Siemens Switzerland Limited

Certified Products	Description	LPCB Ref. No.
	indicating equipment Incorporating as modular units: FCM7204-Z3 Operating unit FTI2001-A1 Fire terminal board FHA2001-A1 Rear housing and as optional modular units: FCM7205-Y3 Operating unit (+ LED Ind.) FCM7203-H3 Operating unit (+ EVAC-Term.) FCM2027 PMI- & mainboard FTO2001-A1 Event printer FTO2002-A1 24 LED indicator (internal) FN2001-A1 Networking module (See Note 1) FN2008-A1 Ethernet Switch (See Note 1) FCA2001-A1 Isolated RS232 module FCA2002-A1 Isolated RS485 module FP2001-A1 70W Power supply H28G200 Housing base REDUX Redundancy module Note: 1. Scope of approval does not include the operation of the network functionality. 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB	Wasantha Hunukumbure	21 October 2013	21 March 2011
	Verifier	Date of Issue	Date of First Issue