
10, rue Ampère Z.I. - B.P. 114 69685 Chassieu cedex / France Switchboard: +33 (0)4 72 22 17 22 FAX: +33 (0)4 72 22 19.35




Procedure of replacement of battery on 40/50 series:

Please, could you follow these instructions in order to decrease the risks of mounting errors or component damages:

1) Open covers of product and remove all connectors:



 Open the product to separate in two parts: (lower part: power supply and I/O boards and the top part: UC board)



3) Separate top cover and the UC board:





ABB Control - France

10, rue Ampère Z.I. - B.P. 114 69685 Chassieu cedex / France Switchboard: +33 (0)4 72 22 17 22

FAX: +33 (0)4 72 22 19.35




Unsolder and take off the battery: (use a solder iron)



5) Put and solder the new battery: (use a solder iron)

Warning: In order to decrease the risk to destroy the component (battery):

Avoid to make short-circuit during the operation on the battery Avoid to heat too high and during a long time with the solder iron Take care with the position of battery (+/-) see the picture



Typ Panasonic VL 1220/1 7mAh

